

9. Hydrant valve shall be connected to water main by flanged joint.
10. Contractor shall provide bollards as directed by the District, City of Redding, Shasta County or associated Fire authorities.

Section 121.00 – Fire Hydrant Installation
August 19, 2020
Centerville CSD

Approved :


District Manager